

June 4, 2021

To: **Liz Buckton, BSc. (Hons), MCIP, RPP**
Manager, Development Services

Re: Comment number 5.10 *“ In accordance with the geotechnical recommendations, a structural engineer should be consulted to ensure the footing and building design proposed is achievable on the subject lands without impact to neighboring properties or significant change to the building or foundations as even a minor change to the foundation wall could impact a number of other matters such as indoor parking”*

Hello Liz,

Cantilever shoring (Soldier Pile and wood Lagging Wall) without any anchors beyond the shoring wall will be proposed as a temporary shoring during constructions, therefore there are no impacts to the soil behind and existing slope.

The basement walls will act as permanent retaining walls after backfilling.

Please contact me if you have any question or concern.



Regards,

Amir Eghtesadi P.Eng.

Structural Engineer

Interbuild Engineering Inc.