



## Hydraulic Calculations by HydraCALC

Heritage Sprinkler Design  
812 Superior St  
Lasalle, ON N9J 3E6  
226-787-3436

Job Name : MEAFORD RESTAURANT  
Drawing : FP-1  
Location : 26 NELSON ST MEAFORD ON  
Remote Area : 2  
Contract : 23-136  
Data File : 23-135 dining.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** MEAFORD RESTAURANT  
**Location** 26 NELSON ST MEAFORD ON  
**Drawing #** FP-1  
**Contract #** 23-136  
**Date** 6/4/23

**DESIGN**

**Remote area #** 2  
**Remote area location** 2ND FLR DINING  
**Occupancy classification** LIGHT  
**Density** .1 - Gpm/SqFt  
**Area of application** 950 - SqFt  
**Coverage/sprinkler** 168 - SqFt  
**Type of sprinkler calculated** K-5.6 QR BR UPR  
**# Sprinklers calculated** 8  
**In-rack demand** - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 282.665 - GPM @ 41.9539 - Psi  
**Type of system** WET  
**Volume of system (dry or pre-action)** - Gal

**WATER SUPPLY INFORMATION**

**Test date** 6/5/23  
**Location** NELSON AND BAYFIELD  
**Source of info** 71-67-1267

**CONTRACTOR INFO** Heritage Sprinkler Design / Miller Fire Prevention  
**Address** 812 Superior St / Lasalle, ON N9J 3E6  
**Phone #** 226-787-3436  
**Name of designer** PAF  
**Authority having jurisdiction**

**NOTES:**

text1(35) - invisible

# Water Supply Curve

Heritage Sprinkler Design  
MEAFORD RESTAURANT


Page 2  
Date 6/4/23

### City Water Supply:

C1 - Static Pressure : 71  
C2 - Residual Pressure: 67  
C2 - Residual Flow : 1267

### Demand:

D1 - Elevation : 18.623  
D2 - System Flow : 182.665  
D2 - System Pressure : 41.954  
Hose ( Demand ) : 100  
D3 - System Demand : 282.665  
Safety Margin : 28.797



# Fittings Used Summary

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 3  
Date 6/4/23

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	23	25	0	0	0
E	90 - NFPA	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	TEE - NFPA	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90 - GROOVED	0	0	1.7	2.2	2.6	3.5	4.3	5	0	6.8	8.5	10	13	17	20	24.5	28	31	34	42
X	TEE - GROOVED	0	0	4.2	5.3	6.4	8.5	10.8	13	0	16	21	25	33	41	50	70	80	90	100	120
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 4  
Date 6/4/23

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
CITY	71.0	67	1267.0	70.751	282.67	41.954

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
201	25.0	5.6	18.0	23.76	0.1 150
201A	25.0	5.6	18.23	23.91	0.1 150
202	45.0	5.6	7.0	14.82	0.1 120
203	25.0		18.47		
204	25.0	5.6	19.41	24.67	0.1 150
206	25.0	5.6	17.2	23.22	0.1 150
207	25.0	5.6	17.41	23.37	0.1 150
208	25.0	5.6	18.19	23.89	0.1 150
210	25.0	5.6	19.97	25.03	0.1 150
211	25.0		20.28		
209	25.0		20.3		
205	25.0		20.56		
212	2.0		31.1		
T2SR	2.0		35.03		
B2SR	-6.0		41.22		
SPGT	-6.0		44.26		
UG1	-6.0		45.23		
CITY	2.0		41.95	100.0	

# Final Calculations : Hazen-Williams

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 5  
Date 6/4/23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
201 to 201A	25 25	5.60	23.76	1.5			12.500	120	18.004 0.0			
			23.76	1.682			12.500	0.0180	0.225	Vel =	3.43	
201A to 203	25 25	5.60	23.91	1.5			3.750	120	18.229 0.0			
			47.67	1.682			3.750	0.0651	0.244	Vel =	6.88	
203			0.0 47.67						18.473	K Factor =	11.09	
202 to 203	45 25	5.60	14.82	1	2E T	4.0 5.0	28.625 9.000	120	7.000 8.662			
			14.82	1.049			37.625	0.0747	2.811	Vel =	5.50	
203 to 204	25 25		47.67	1.5			8.750	120	18.473 0.0			
			62.49	1.682			8.750	0.1074	0.940	Vel =	9.02	
204 to 205	25 25	5.60	24.67	1.5			5.791	120	19.413 0.0			
			87.16	1.682			5.791	0.1988	1.151	Vel =	12.59	
205			0.0 87.16						20.564	K Factor =	19.22	
206 to 207	25 25	5.60	23.22	1.5			12.500	120	17.198 0.0			
			23.22	1.682			12.500	0.0173	0.216	Vel =	3.35	
207 to 208	25 25	5.60	23.37	1.5			12.500	120	17.414 0.0			
			46.59	1.682			12.500	0.0624	0.780	Vel =	6.73	
208 to 209	25 25	5.60	23.89	1.5	T	9.9	5.791 9.900	120	18.194 0.0			
			70.48	1.682			15.691	0.1342	2.106	Vel =	10.18	
209			0.0 70.48						20.300	K Factor =	15.64	
210 to 211	25 25	5.60	25.03	1.5	T	9.9	5.791 9.900	120	19.972 0.0			
			25.03	1.682			15.691	0.0198	0.310	Vel =	3.61	
211 to 209	25 25		0.0	2.5			8.000	120	20.282 0.0			
			25.03	2.635			8.000	0.0022	0.018	Vel =	1.47	
209 to 205	25 25		70.47	2.5			10.000	120	20.300 0.0			
			95.5	2.635			10.000	0.0264	0.264	Vel =	5.62	
205 to 212	25 2		87.16	2.5	V	5.903	0.666 5.903	120	20.564 9.961			
			182.66	2.635			6.569	0.0878	0.577	Vel =	10.75	
212 to T2SR	2 2		0.0	2.5	3V	17.71	27.000 17.710	120	31.102 0.0			
			182.66	2.635			44.710	0.0878	3.926	Vel =	10.75	
T2SR to B2SR	2 -6		0.0	2.5	B T	9.61 16.474	5.000 26.084	120	35.028 3.465			
			182.66	2.635			31.084	0.0878	2.729	Vel =	10.75	

# Final Calculations : Hazen-Williams

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 6  
Date 6/4/23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
B2SR to SPGT	-6 -6		0.0 182.66	4 4.26	Zib 2V X	0.0 17.907 21.067	9.000 38.974 47.974	120 0.0085	41.222 2.629 0.406		** Fixed Loss = 2.629 Vel = 4.11	
SPGT to UG1	-6 -6		0.0 182.66	4 4.1	E G T	10.928 2.186 21.855	60.000 34.969 94.969	120 0.0102	44.257 0.0 0.969		Vel = 4.44	
UG1 to CITY	-6 2		0.0 182.66	6 6.16	T	43.037 43.037 183.037	140.000 43.037 183.037	140 0.0011	45.226 -3.465 0.193		Vel = 1.97	
CITY			100.00 282.66						41.954		Qa = 100.00 K Factor = 43.64	