



## Hydraulic Calculations by HydraCALC

Heritage Sprinkler Design  
812 Superior St  
Lasalle, ON N9J 3E6  
226-787-3436

Job Name : MEAFORD RESTAURANT  
Drawing : FP-1  
Location : 26 NELSON ST MEAFORD ON  
Remote Area : 1  
Contract : 23-136  
Data File : 23-135 retail.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** MEAFORD RESTAURANT  
**Location** 26 NELSON ST MEAFORD ON  
**Drawing #** FP-1  
**Contract #** 23-136  
**Date** 6/4/23

**DESIGN**

**Remote area #** 1  
**Remote area location** RETAIL  
**Occupancy classification** OH-2  
**Density** .2 - Gpm/SqFt  
**Area of application** 1050 - SqFt  
**Coverage/sprinkler** 117 - SqFt  
**Type of sprinkler calculated** K-5.6 QR BR UPR/TY3488 WINDOW  
**# Sprinklers calculated** 12  
**In-rack demand** - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 550.204 - GPM @ 61.0189 - Psi  
**Type of system** WET  
**Volume of system (dry or pre-action)** - Gal

**WATER SUPPLY INFORMATION**

**Test date** 6/5/23  
**Location** NELSON AND BAYFIELD  
**Source of info** 71-67-1267

**CONTRACTOR INFO** Heritage Sprinkler Design / Miller Fire Prevention  
**Address** 812 Superior St / Lasalle, ON N9J 3E6  
**Phone #** 226-787-3436  
**Name of designer** PAF  
**Authority having jurisdiction**

**NOTES:**

WINDOW SPRINKLERS BALANCED IN CALC

text1(35) - invisible

# Water Supply Curve

Heritage Sprinkler Design  
MEAFORD RESTAURANT


Page 2  
Date 6/4/23

### City Water Supply:

C1 - Static Pressure : 71  
C2 - Residual Pressure: 67  
C2 - Residual Flow : 1267

### Demand:

D1 - Elevation : 5.630  
D2 - System Flow : 300.204  
D2 - System Pressure : 61.019  
Hose ( Demand ) : 250  
D3 - System Demand : 550.204  
Safety Margin : 9.126



# Fittings Used Summary

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 3  
Date 6/4/23

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	23	25	0	0	0
E	90 - NFPA	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	TEE - NFPA	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90 - GROOVED	0	0	1.7	2.2	2.6	3.5	4.3	5	0	6.8	8.5	10	13	17	20	24.5	28	31	34	42
X	TEE - GROOVED	0	0	4.2	5.3	6.4	8.5	10.8	13	0	16	21	25	33	41	50	70	80	90	100	120
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
Length Units               Feet  
Flow Units                 US Gallons per Minute  
Pressure Units             Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 4  
Date 6/4/23

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
CITY	71.0	67	1267.0	70.145	550.2	61.019

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
101	15.0	5.6	16.87	23.0	0.2 115
102	15.0	5.6	17.03	23.11	0.2 115
103	15.0	5.6	17.63	23.51	0.2 115
104	15.0	5.6	18.91	24.35	0.2 115
105	15.0	5.6	21.14	25.75	0.2 115
107	15.0	5.6	17.2	23.22	0.2 115
108	15.0	5.6	17.36	23.33	0.2 115
109	15.0	5.6	17.97	23.74	0.2 115
110	15.0	5.6	19.27	24.58	0.2 115
111	15.0	5.6	21.54	25.99	0.2 115
106	15.0		24.49		
112	15.0		24.95		
113	2.0		45.72		
T1SR	2.0		49.64		
B1SR	-6.0		57.65		
SPGT	-6.0		61.57		
UG1	-6.0		64.0		
CITY	2.0		61.02	250.0	
901	9.0	5.6	27.93	29.6	0.1 150
902	9.0	5.6	28.72	30.01	0.1 150
903	9.0		34.58		
904	-1.0		41.57		
TWSR	-1.0		51.76		
BWSR	-6.0		57.65		

# Final Calculations : Hazen-Williams

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 5  
Date 6/4/23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
101 to 102	15 15	5.60	23.00 23.0	1.5 1.682			9.750 9.750	120 0.0169	16.869 0.0 0.165		Vel = 3.32	
102 to 103	15 15	5.60	23.11 46.11	1.5 1.682			9.750 9.750	120 0.0611	17.034 0.0 0.596		Vel = 6.66	
103 to 104	15 15	5.60	23.52 69.63	1.5 1.682			9.750 9.750	120 0.1313	17.630 0.0 1.280		Vel = 10.05	
104 to 105	15 15	5.60	24.35 93.98	1.5 1.682			9.750 9.750	120 0.2285	18.910 0.0 2.228		Vel = 13.57	
105 to 106	15 15	5.60	25.74 119.72	1.5 1.682	Eqi	8.662	0.708 8.662 9.370	120 0.3577	21.138 0.0 3.352		Vel = 17.29	
106			0.0 119.72						24.490		K Factor = 24.19	
107 to 108	15 15	5.60	23.22 23.22	1.5 1.682			9.750 9.750	120 0.0172	17.195 0.0 0.168		Vel = 3.35	
108 to 109	15 15	5.60	23.34 46.56	1.5 1.682			9.750 9.750	120 0.0623	17.363 0.0 0.607		Vel = 6.72	
109 to 110	15 15	5.60	23.74 70.3	1.5 1.682			9.750 9.750	120 0.1336	17.970 0.0 1.303		Vel = 10.15	
110 to 111	15 15	5.60	24.58 94.88	1.5 1.682			9.750 9.750	120 0.2326	19.273 0.0 2.268		Vel = 13.70	
111 to 112	15 15	5.60	25.99 120.87	1.5 1.682	Eqi	8.662	0.708 8.662 9.370	120 0.3640	21.541 0.0 3.411		Vel = 17.45	
112			0.0 120.87						24.952		K Factor = 24.20	
106 to 112	15 15		119.72 119.72	2.5 2.635			11.500 11.500	120 0.0402	24.490 0.0 0.462		Vel = 7.04	
112 to 113	15 2		120.88 240.6	2.5 2.635	2X 4V	29.654 23.613	50.333 53.267 103.600	120 0.1462	24.952 5.630 15.142		Vel = 14.16	
113 to T1SR	2 2		0.0 240.6	2.5 2.635	2V	11.807	15.000 11.807 26.807	120 0.1462	45.724 0.0 3.919		Vel = 14.16	
T1SR to B1SR	2 -6		0.0 240.6	2.5 2.635	B T	9.61 16.474	5.000 26.084 31.084	120 0.1462	49.643 3.465 4.543		Vel = 14.16	
B1SR to SPGT	-6 -6		59.60 300.2	4 4.26	Zib 2V X	0.0 17.907 21.067	9.000 38.974 47.974	120 0.0212	57.651 2.903 1.017		** Fixed Loss = 2.903 Vel = 6.76	

# Final Calculations : Hazen-Williams

Heritage Sprinkler Design  
MEAFORD RESTAURANT

Page 6  
Date 6/4/23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SPGT to UG1	-6 -6		0.0 300.2	4 4.1	E G T	10.928 2.186 21.855	60.000 34.969 94.969	120 0.0256	61.571 0.0 2.428			Vel = 7.30
UG1 to CITY	-6 2		0.0 300.2	6 6.16	T	43.037	140.000 43.037 183.037	140 0.0026	63.999 -3.465 0.485			Vel = 3.23
CITY			250.00 550.20						61.019			Qa = 250.00 K Factor = 70.43
901 to 903	9 9	5.60	29.60 29.6	1 1.049	3E 2T	6.0 10.0	8.750 16.000 24.750	120 0.2687	27.932 0.0 6.651			Vel = 10.99
903			0.0 29.60						34.583			K Factor = 5.03
902 to 903	9 9	5.60	30.01 30.01	1 1.049	2E 2T	4.0 10.0	7.250 14.000 21.250	120 0.2757	28.724 0.0 5.859			Vel = 11.14
903 to 904	9 -1		29.60 59.61	1.25 1.442	V	2.725	10.000 2.725 12.725	120 0.2083	34.583 4.331 2.651			Vel = 11.71
904 to TWSR	-1 -1		0.0 59.61	1.25 1.442	3V	8.175	40.750 8.175 48.925	120 0.2084	41.565 0.0 10.195			Vel = 11.71
TWSR to BWSR	-1 -6		0.0 59.61	2 2.157	B Fsp T	7.384 0.0 12.307	5.000 19.691 24.691	120 0.0293	51.760 5.166 0.723		** Fixed Loss = 3	Vel = 5.23
BWSR to B1SR	-6 -6		0.0 59.61	4 4.26			1.500 1.500	120 0.0013	57.649 0.0 0.002			Vel = 1.34
B1SR			0.0 59.61						57.651			K Factor = 7.85